



**School District of Osceola County**

**ANNUAL COMPREHENSIVE SAFETY INSPECTION**

For School Year 07/01/17 to 06/30/18

Inspection Date: 04/09/18

**Fish Number:** 0853

**School:** New Dimensions High School

**Address:** 1900 Old Pleasant Hill Road

**City:** Kissimmee

**State:** Florida

**Zip Code:** 34759

Fire Code	RuleID	Priority	Bldg	Room	Est Cost	Type	Deficiency	Times Cited	Cor Period
199	13(x)	B	100	006a	\$0.00	O	Storage needs removed	1	60
	8(a)	C	100	105	\$300.00	M	Door needs to be repaired/replaced	0	30
299	101-15.2.2.2.2	C	100	corr.	\$500.00	M	Door needs panic hardware repaired/installed	0	30
	17(b)	B	200	207	\$0.00	O	Cord running across door/ceiling/aisle must be removed	0	60
	10(b)	B	300	301	\$0.00	O	Door vision panel is covered - keep clear	0	60
	8(d)	B	300	302	\$0.00	M	Glazing/mirrors/glass is broken and needs replaced.	0	60
	1(e)8j	B	300	gst	\$0.00	O	Clean dirty floor/carpet	0	60
	1(e)8h	B	300	gym	\$0.00	O	Light bulb needs to be replaced	1	60
599	25-4.1	F	400	400d	\$0.00	O	Fire sprinkler riser access is obstructed - keep clear	0	30
	N/A	N	500	0000	\$0.00	N	No deficiencies noted	0	0

Inspector Signature: Jo Beekman Date of Inspection: 4/9/2018 Telephone Number: 407-892-6762  
 Print Name: Jo Beekman Address: 817 Bill Beck Blvd., Kissimmee, Florida 34744  
 For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY: Emergency Evacuation Drills Held Once Every Month Yes / No  
 Approval of Reports by Board (including letter) Yes / No The District has complied with Section 1013.12(1)(c) F.S. Yes / No  
 Signature of Facility Administrator attesting to Emergency Evacuation Drills and Review of Report Acknowledging awareness of discovered deficiencies:  
 Administrator Signature: Jan D. Gwin Date: 4-30-18